

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
246	Arbor	06/28/12	D	248		Baffles intact; Clean cast. & Lid	995
247	Arbor	06/25/12	S			Baffles intact; Clean cast. & Lid	720
248	Arbor	06/28/12	D	246		Baffles intact; Clean cast. & Lid	500
249	Arbor	06/28/12	S			Baffles intact; Clean cast. & Lid	890
251	Arbor	06/28/12	D	253		Baffles intact; Clean cast. & Lid	255
252	Arbor	06/28/12	S			Baffles intact; Clean cast. & Lid	1275
253	Arbor	06/28/12	D	251	On Brummitt Park	Baffles intact; Clean cast. & Lid	520
254	Arbor		S				1040
255	Arbor	07/10/12	D	257		Baffles intact; Clean cast. & Lid	430
256	Arbor	07/28/16	D>		W/ 750 Br Pk On Br Pk	Baffles intact; Clean cast & Lid	1135
257	Arbor	07/10/12	D	255		Baffles intact; Clean cast. & Lid	425
258	Arbor	06/25/12	D	260		Baffles intact; Clean cast. & Lid	1390
259	Arbor	06/25/12	D	261		Baffles intact; Clean cast. & Lid	935
260	Arbor	06/25/12	D	258		Baffles intact; Clean cast. & Lid	1100
261	Arbor	06/25/12	D	259		Baffles intact; Clean cast. & Lid	780
262	Arbor	06/25/12	S			Baffles intact; Clean cast. & Lid	460
263	Arbor	07/02/12	D	265		Baffles intact; Clean cast. & Lid, replace seal	655
264	Arbor	07/02/12	D	266		Baffles intact; Clean cast. & Lid, replace seal	375
265	Arbor	07/02/12	D	263		Baffles intact; Clean cast. & Lid, replace seal	70
266	Arbor	07/02/12	D	264		Baffles intact; Clean cast. & Lid, replace seal	285
267	Arbor	10/26/15	S			Baffles intact; Clean cast. & Lid	1395
268	Arbor	07/10/12	S			Baffles intact. Concrete Lid.	1540
269	Arbor	07/02/12	S			Baffles intact; Clean cast. & Lid	575
270	Arbor	07/02/12	S			Baffles intact; Clean cast. & Lid	1470
271	Arbor	06/29/12	D	273		Baffles intact; Clean cast. & Lid, replace seal	325
273	Arbor	06/29/12	D	271		Baffles intact; Clean cast. & Lid, replace seal	1150
274	Arbor	06/29/12	S			Baffles intact; Clean cast. & Lid	765
276	Arbor	07/25/12	D>		W/ 1302 Brummitt Rd	Baffles intact; Clean cast. & Lid	950
1262	Arbutus	08/26/16	D	1266		Baffles intact; Clean cast. & Lid	120

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
1263	Arbutus	08/23/16	D	1267		Baffles intact; Clean cast. & Lid	210
1266	Arbutus	08/26/16	D	1262		Baffles intact; Clean cast. & Lid	1260
1267	Arbutus	08/23/16	D	1263		Baffles intact; Clean cast. & Lid	885
1270	Arbutus	08/31/16	D>		W/ Vac Lot Ind Bndry	Baffles intact; Clean cast. & Lid	975
1271	Arbutus	10/23/15	S		Was 216 Ind Bndry	Baffles intact; Clean cast. & Lid	1105
2335	Architect	08/02/12	S		On Park Rd	Baffles intact; Clean cast. & Lid	140
2350	Architect	07/02/12	S			Baffles intact; Clean cast. & Lid	385
2390	Architect	07/19/11	D	2402		Baffles intact; Seal OK	675
2402	Architect	07/19/11	D	2390		Baffles intact; Seal OK	1370
2501	Architect	08/26/16	S			Baffles intact; Clean cast. & Lid	30
2502	Architect	08/23/16	D	2602		Baffles intact; Clean cast. & Lid	1325
2602	Architect	08/23/16	D	2502		Baffles intact; Clean cast. & Lid	990
510	Brummitt Pk Dr	07/10/12	D	530		Baffles intact; clean cast. & lid, replace seal	875
530	Brummitt Pk Dr	07/10/12	D	510		Baffles intact; clean cast. & lid, replace seal	365
531	Brummitt Pk Dr	07/31/12	D	551		Baffles intact; Clean cast. & Lid	225
550	Brummitt Pk Dr	07/02/12	D	570	Set Back	Baffles intact; Clean cast. & Lid	1000
551	Brummitt Pk Dr	07/31/12	D	531		Baffles intact; Clean cast. & Lid	1180
561	Brummitt Pk	08/23/16	D>		W/ 2502 Riverview	Baffles intact; Clean cast. & Lid	635
570	Brummitt Pk Dr	07/02/12	D	550		Baffles intact; Clean cast. & Lid	665
595	Brummitt Pk	08/26/16	S		On Riverview	Baffles intact; Clean cast. & Lid	860
750	Brummitt Pk	07/28/16	D>		W/ 256 Arbor	Baffles intact; Clean cast. & Lid	220
1268	Brummitt Rd	11/10/15	S			Baffles intact; cast. Lid & seal good shape	1155
1276	N. Brummitt Rd	08/17/16	S			Baffles intact; Clean cast. & Lid	55
1277	Brummitt Rd	08/03/12	S			Baffles intact; Clean cast. & Lid	350
1278	N. Brummitt Rd	08/17/16	S			Baffles intact; Clean cast. & Lid	1075
1282	N. Brummitt Rd	08/17/16	S			Baffles intact; Clean cast. & Lid	45
1284	Brummitt Rd	08/15/12	S		STEP (Lift Sta - Special Tk w/ effluent pump)	Replaced Control Enclosure 4/4/12 Sta Inspected 08/08/12 Added Viper Cellular Monitoring Unit to Controls 10/09/12	880
1285	N. Brummitt Rd	08/03/16	S			Baffles intact; Clean cast. & Lid	585

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with */*/12 Pump Dates will be scheduled for 2017 Spring Clean Outs for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
1286	N. Brummitt Rd	08/17/16	S		On Mar Mar Loop	Baffles intact; Clean cast. & Lid	405
1288	N. Brummitt Rd	08/31/16	D	1292		Baffles intact; Clean cast. & Lid	1435
1292	N. Brummitt Rd	08/31/16	D	1288		Baffles intact; Clean cast. & Lid	1120
1294	N. Brummitt Rd	07/06/12	S			Baffles intact; Clean cast. & Lid	760
1298	N. Brummitt Rd	07/25/12	S			Baffles intact; Clean cast. & Lid	1065
1302	N. Brummitt Rd	07/25/12	D>		W/ 276 Arbor	Baffles intact; Clean cast. & Lid	450
1303	N. Brummitt Rd	07/24/12	D	1305		Baffles intact; Clean cast. & Lid	1080
1305	N. Brummitt Rd	07/24/12	D	1303		Baffles intact; Clean cast. & Lid	185
1306	N. Brummitt Rd	08/15/12	S		New 4/96	Baffles intact; Plastic riser and cap	1520
205	Dogwood	08/20/15	D>		W/ 392 Wake Robin	Baffles intact; Clean cast. & Lid	1310
209	Dogwood	08/20/15	S			Baffles intact; Clean cast. & Lid	490
211	Dogwood	08/25/15	S			Baffles intact; cast. Lid & seal good shape	485
215	Dogwood	08/25/15	S		On Arbutus	Baffles intact; Clean cast. & Lid	260
217	Dogwood	08/26/15	S			Baffles intact; Clean cast. & Lid	590
218	Dogwood	08/26/15	D	1690	On Arbutus	Baffles intact; Clean cast. & Lid Needs new seal	555
219	Dogwood	08/26/15	D	221		Baffles intact; Clean cast. & Lid Needs new seal	115
221	Dogwood	08/26/15	D	219	On Violet	Baffles intact; Clean cast. & Lid Needs new seal	1410
222	Dogwood	08/26/15	S			Baffles intact; cast. Lid & seal OK	25
223	Dogwood	08/26/15	S			Baffles intact; Clean cast. & Lid	1095
224	Dogwood	08/26/15	D	226		Baffles intact; Clean cast. & Lid	1320
225	Dogwood	08/26/15	D>		W/ 1264 Redbud	Baffles intact; Clean cast. & Lid	705
226	Dogwood	08/26/15	D	224		Baffles intact; Clean cast. & Lid	1035
1217	Dogwood	09/04/15	D	1219		Baffles intact; Clean cast. & Lid	40
1218	Dogwood	09/09/15	S			Baffles intact; Clean cast. & Lid	695
1219	Dogwood	09/09/15	D	1217		Baffles intact; Clean cast. & Lid	110
1220	Dogwood	09/09/15	S			Baffles intact; Clean cast. & Lid	1210
1221	Dogwood	08/26/16	D	1223		Baffles intact; Clean cast. & Lid	630
1222	Dogwood	08/02/16	D	1224		Baffles intact; Clean cast. & Lid	1170
1223	Dogwood	08/26/16	D	1221		Baffles intact; Clean cast. & Lid	345
1224	Dogwood	08/02/16	D	1222		Baffles intact; Clean cast. & Lid	1205
1225	Dogwood	08/23/16	D	1227		Baffles intact; Clean cast. & Lid	310
1226	Dogwood	08/05/16	D	1228		Baffles intact; Clean cast. & Lid	125

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
1227	Dogwood	08/23/16	D	1225		Baffles intact; Clean cast. & Lid	130
1228	Dogwood	08/05/16	D	1226		Baffles intact; Clean cast. & Lid	550
1229	Dogwood	10/20/15	S			Baffles intact; Clean cast. & Lid	965
1230	Dogwood	08/31/16	D	1232		Baffles intact; Clean cast. & Lid	1025
1231	Dogwood	10/20/15	S			Baffles intact; Clean cast. & Lid	535
1232	Dogwood	08/31/16	D	1230		Baffles intact; Clean cast. & Lid	1225
1233	Dogwood	07/31/12	S			Baffles intact; Clean cast. & Lid	205
1234	Dogwood	08/17/16	D	1236		Baffles intact; Clean cast. & Lid	1265
1235	Dogwood	08/31/16	D	1237	Disconnected	Baffles intact; Clean cast. & Lid	740
1236	Dogwood	08/17/16	D	1234		Baffles intact; Clean cast. & Lid	785
1237	Dogwood	08/31/16	D	1235		Baffles intact; Clean cast. & Lid	1125
1238	Dogwood	08/03/16	D	1242		Baffles intact; Clean cast. & Lid	605
1239	Dogwood	09/04/15	D	1241		Baffles intact; Clean cast. & Lid	220
1241	Dogwood	09/04/15	D	1239		Baffles intact; Clean cast. & Lid	1440
1242	Dogwood	08/03/16	D	1238		Baffles intact; Clean cast. & Lid	725
1243	Dogwood	10/19/15	S			Baffles intact; Clean cast. & Lid	1430
1245	Dogwood	09/09/15	D	1247		Baffles intact; Clean cast. & Lid	830
1246	Dogwood	10/20/15	D	1248		Baffles intact; Clean cast. & Lid	1010
1247	Dogwood	09/09/15	D	1245		Baffles intact; Clean cast. & Lid	595
1248	Dogwood	10/20/15	D	1246		Baffles intact; Clean cast. & Lid	1385
1249	Dogwood	10/20/15	D	1251		Baffles intact; Clean cast. & Lid	1175
1250	Dogwood	10/19/15	D	1252		Baffles intact; Clean cast. & Lid	755
1251	Dogwood	10/20/15	D	1249		Baffles intact; Clean cast. & Lid	1375
1252	Dogwood	10/19/15	D	1250		Baffles intact; Clean cast. & Lid	395
1253	Dogwood	10/10/15	D	1255	w/ 1255 Dogwood	Baffles intact; Clean cast. & Lid	920
1254	Dogwood	10/21/15	D>		W/ 1255 Redbud	Baffles intact; Clean cast. & Lid	1380
1255	Dogwood	10/19/15	D	1253	New 1/96 Miller	Baffles intact; Clean cast. & Lid	1515
1257	Dogwood	10/19/15	S			Baffles intact; Clean cast. & Lid	930
1660	Dogwood	08/05/16	S			Baffles intact; Clean cast. & Lid	1160
1690	Dogwood	08/26/15	D	218		Baffles intact; Clean cast. & Lid Needs new seal	5
501	Graham				No Tank		215
502	Graham				No Tank		735
530	Graham	07/03/12	D	560		Baffles intact; Clean cast & Lid	910
531	Graham	07/03/12	S			Baffles intact; Clean cast & Lid	95

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
551	Graham	07/31/12	D	561		Baffles intact; Clean cast & Lid	1250
560	Graham	07/03/12	D	530		Baffles intact; Clean cast & Lid	315
561	Graham	07/31/12	D	551		Baffles intact; Clean cast & Lid	850
590	Graham	07/06/12	D	598		Baffles intact; Clean cast & Lid	900
591	Graham	10/19/15	D	601		Baffles intact; Clean cast & Lid	175
598	Graham	07/06/12	D	590		Baffles intact; Clean cast & Lid	1295
601	Graham	10/19/15	D	591		Baffles intact; Clean cast & Lid	810
611	Graham	07/03/12	D	617		Baffles intact; Clean cast & Lid	1455
617	Graham	07/03/12	D	611		Baffles intact; Clean cast & Lid	1070
621	Graham	07/03/12	S			Baffles intact; Clean cast & Lid	455
631	Graham	07/09/12	D	661		Baffles intact; Clean cast & Lid	50
650	Graham	07/12/12	S			Baffles intact; clean cast. & Lid	340
661	Graham	07/09/12	D	631		Baffles intact; Clean cast & Lid	280
691	Graham	07/09/12	D	701		Baffles intact; Clean cast & Lid	565
700	Graham	07/09/12	D	750		Baffles intact; Clean cast & Lid	887
701	Graham	07/09/12	D	691		Baffles intact; Clean cast & Lid	1190
731	Graham	08/17/16	S			Baffles intact; Clean cast. & Lid	380
750	Graham	07/09/12	D	700		Baffles intact; Clean cast & Lid	940
761	Graham	07/09/12	S			Baffles intact; clean cast. & Lid	1290
790	Graham	07/09/12	S		On Park Dr	Baffles intact; clean cast. & Lid	35
791	Graham	04/12/13	Dual Pump Well		Gr Dr Lift Station	Pumped and Powerwashed	
795	Graham	10/19/15	D	1820		Baffles intact; Casting cleaned, Seal OK	610
1605	Graham	07/28/16	S			Baffles intact; Clean cast & Lid	745
1624	Graham	07/10/12	S		W/ Vacant Lot	Baffles intact; Clean cast & Lid	1015
1625	Graham	07/10/12	D	1635		Baffles intact; Clean cast & Lid	1030
1635	Graham	07/10/12	D	1625		Baffles intact; Clean cast & Lid	915
1660	Graham	07/23/12	S			Baffles intact; Clean cast & Lid	820
1665	Graham	07/10/12	S			Baffles intact; Clean cast & Lid	510
1690	Graham	10/19/15	D	1730		Baffles intact; Casting cleaned, Seal OK	770
1695	Graham	07/19/12	S			Baffles intact; Clean cast & Lid	1245
1725	Graham	07/19/12	D	1765		Baffles intact; Clean cast & Lid	980
1730	Graham	10/19/15	D	1690		Baffles intact; Casting cleaned, Seal OK	625
1760	Graham	07/19/12	S			Baffles intact; Clean cast & Lid	65
1765	Graham	07/19/12	D	1725		Baffles intact; Clean cast & Lid	1235

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates will be scheduled for 2017 Spring Clean Outs for their 5 year cycle.**

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
1790	Graham	07/19/12	D	1810		Baffles intact; Clean cast & Lid	245
1795	Graham	07/19/12	D	1805		Baffles intact; Clean cast & Lid	90
1805	Graham	07/19/12	D	1795		Baffles intact; Clean cast & Lid	1195
1810	Graham	07/19/12	D	1790		Baffles intact; Clean cast & Lid	1200
1820	Graham	10/19/15	D	795		Baffles intact; Casting cleaned, Seal OK	1450
1825	Graham	07/24/12	S		On Lake Drive	Baffles intact; clean cast. & Lid	1185
1835	Graham	07/24/12	S		On Lake Drive	Baffles intact; clean cast. & Lid	893
501	Honeyshade	08/15/12	D>		W/1875 InBdry on InBdry	Baffles intact; Clean cast & Lid	465
502	Honeyshade	07/25/12	S		On In Bdry	Baffles intact; clean cast. & Lid	335
520	Honeyshade	07/19/12	D	540		Baffles intact; Clean cast & Lid	540
521	Honeyshade	07/25/12	D	541		Baffles intact; Clean cast & Lid	1005
540	Honeyshade	07/19/12	D	520		Baffles intact; Clean cast & Lid	1315
541	Honeyshade	07/25/12	D	521		Baffles intact; Clean cast & Lid	1280
561	Honeyshade	07/31/12	S			Baffles intact; clean cast. & Lid	1060
1475	In Bdry	08/10/12	S			Pump station	435
1498	In Bdry	08/09/12	S			Baffles intact; clean cast. & lid	865
1501	In Bdry	08/10/12	S		STEP (Lift Sta - Special Tk w/ effluent pump)	Sta Inspected 08/08/12 Added Viper Cellular Monitoring Unit to Controls 10/10/12	415
1505	In Bdry	08/10/12	S		STEP (Lift Sta - Special Tk w/ effluent pump)	Sta Inspected - Changed Out Floats 08/08/12 Added Viper Cellular Monitoring Unit to Controls- 10/10/12	240
1530	In Bdry	08/01/12	S			Baffles intact; clean cast. & lid	270
1550	In Bdry	08/02/12	S			Baffles intact; clean cast. & lid	1050
1551	In Bdry	08/03/12	S			Baffles intact; clean cast. & lid	10
1569	In Bdry	08/15/12	D>		W/ 501 Honeyshade	Baffles intact; Clean cast & Lid	1545
1570	In Bdry	10/23/15	D>		W/ 1270 Wake Robin	Baffles intact; Casting cleaned, Seal OK	730
1650	In Bdry	08/26/16	D>		W/ 1271 Wake Robin	Baffles intact; Clean cast & Lid	1230

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
1660	In Bdry	08/01/12	D	1680		Baffles intact; Clean cast & Lid	645
1665	In Bdry	08/01/12	D	1695		Baffles intact; Clean cast & Lid	180
1680	In Bdry	08/01/12	D	1660		Baffles intact; Clean cast & Lid	165
1695	In Bdry	08/01/12	D	1665		Baffles intact; Clean cast & Lid	1350
1735	In Bdry	08/08/12	S			Baffles intact; clean cast. & lid	1045
1765	In Bdry	08/17/16	D>		W/ 501 Starwood	Baffles intact; Clean cast & Lid	1165
1776	In Bdry	08/08/12	S			Baffles intact; clean cast. & lid	1500
1780	In Bdry	07/10/13	S		STEP (Lift Sta - Special Tk w/ effluent pump)	STEP Pump Replaced 3/05/12 Sta Inspected-Replaced Bad Alarm Float 08/08/12 Added Viper Cellular Monitoring Unit to Controls-10/10/12 Replaced Holding Tank 07/10/13	835
1800	In Bdry	08/10/12	S		STEP (Lift Sta - Special Tk w/ effluent pump)	Sta Inspected 08/08/12 Added Viper Cellular Monitoring Unit to Controls- Replaced Alarm Light 10/10/12	195
1835	In Bdry	08/08/12	S			Baffles intact; clean cast. & lid	825
1845	In Bdry	2009	Dual Pump Well		IBR Main Lift Station	Pumped when well rails and pump bases repaired.	
1960	In Bdry				No Tank		1115
2355	In Bdry				No Tank		100
2375	In Bdry				No Tank		750
2500	In Bdry		None		Brummitt Elem School	NO Tank Found-Local Manhole w/ direct feed to Main Sewer System on Ind Bndry Rd	
2601	In Bdry	11/10/15	S		Plan Incomplete	Baffles intact; Casting OK, needs new Lid/Seal	273
1202	Lake	11/10/15	S			Baffles intact; Casting cleaned, Seal OK	1305
1206	Lake	11/10/15	S			Baffles intact; Casting cleaned, Seal OK	1215
1301	Lake	07/12/12	D	1305		Baffles intact; Clean cast & Lid	925
1305	Lake	07/12/12	D	1301		Baffles intact; Clean cast & Lid	905
730	Mar Mar	08/31/16	S			Baffles intact; Clean cast & Lid	410

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
751	Mar Mar	10/20/15	D	801		Baffles intact; Casting cleaned, Seal OK	970
780	Mar Mar	08/31/16	S			Baffles intact; Clean cast & Lid	80
801	Mar Mar	10/20/15	D	751		Baffles intact; Casting cleaned, Seal OK	1130
802	Mar Mar	06/20/11	D	822		Baffles intact; Seal OK	400
822	Mar Mar	06/20/11	D	802		Baffles intact; Seal OK	445
852	Mar Mar	06/20/11	D	904		Baffles intact; Seal OK	60
901	Mar Mar	11/10/15	S		New Mullin 1/98	Both baffles are intact. Tank has a plastic riser. No c	1525
904	Mar Mar	06/20/11	D	852		Baffles intact; Seal OK	200
950	Mar Mar	07/23/12	S		New 4/91	Baffles intact; clean cast & lid	1485
951	Mar Mar	06/20/11	S			Baffles intact; Seal OK	795
226	Michael	10/22/15	D	228		Baffles intact; Casting cleaned, Seal OK	1335
228	Michael	10/22/15	D	226		Baffles intact; Casting cleaned, Seal OK	640
229	Michael	10/26/15	D>		W/ 1219 Redbud	Baffles intact; Cast. & Seal Good shape	1480
230	Michael	10/26/15	S			Baffles intact; Cast. & Seal Good shape	230
232	Michael	10/22/15	D	234		Baffles intact; Casting cleaned, Seal OK	505
234	Michael	10/22/15	D	232		Baffles intact; Casting cleaned, Seal OK	1220
1520	Orchard Lane	08/05/16	D	1560		Baffles intact; Clean cast & Lid	680
1525	Orchard Lane	08/05/16	D	1555		Baffles intact; Clean cast & Lid	1090
1555	Orchard Lane	08/05/16	D	1525	New 12/97	Baffles intact; Clean cast & Lid	1530
1560	Orchard Lane	08/05/16	D	1520		Baffles intact; Clean cast & Lid	1460
1590	Orchard Lane	08/05/16	S			Baffles intact; Clean cast & Lid	660
1201	Park Drive	08/02/12	S			Baffles intact; clean cast. & lid	715
1301	Park Drive	08/02/12	S			Baffles intact; clean cast. & lid	815
1218	Redbud	10/26/15	S			Both baffles are intact. Casting ring was cleaned. Se	355
1219	Redbud	10/26/15	D>		W/ 229 Michael	Both baffles are intact. Casting and Seal are in good	1415
1220	Redbud	06/20/11	D	1222		Baffles intact; Seal OK	480
1221	Redbud	06/20/11	D	1223		Baffles intact; Seal OK	250
1222	Redbud	06/20/11	D	1220		Baffles intact; Seal OK	1360
1223	Redbud	06/20/11	D	1221		Baffles intact; Seal OK	300
1224	Redbud	06/20/11	D	1226		Baffles intact; Seal OK	305
1225	Redbud	06/20/11	D	1227		Baffles intact; Seal OK	495
1226	Redbud	06/20/11	D	1224		Baffles intact; Seal OK	1465

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
1227	Redbud	06/20/11	D	1225		Baffles intact; Seal OK	985
1228	Redbud	06/20/11	D	1230		Baffles intact; Seal OK	1340
1229	Redbud	07/12/12	D	1231		Baffles intact; Clean cast & Lid	135
1230	Redbud	06/20/11	D	1228		Baffles intact; Seal OK	710
1231	Redbud	07/12/12	D	1229		Baffles intact; Clean cast & Lid	960
1232	Redbud	06/20/11	D	1234		Baffles intact; Seal OK	515
1233	Redbud	06/20/11	D	1235		Baffles intact; Seal OK	150
1234	Redbud	06/20/11	D	1232		Baffles intact; Seal OK	1405
1235	Redbud	06/20/11	D	1233		Baffles intact; Seal OK	170
1236	Redbud	06/20/11	D	1238		Baffles intact; Seal OK	840
1237	Redbud	06/20/11	D	1239		Baffles intact; Seal OK	560
1238	Redbud	06/20/11	D	1236		Baffles intact; Seal OK	855
1239	Redbud	06/20/11	D	1237		Baffles intact; Seal OK	955
1241	Redbud	08/18/16	S			Baffles intact; Clean cast & Lid	1330
1242	Redbud	08/18/16	S			Baffles intact; Clean cast & Lid	670
1245	Redbud	07/14/11	D	1247		Baffles intact; Seal OK	1400
1246	Redbud	07/13/11	D	1248	Disconnecting	Baffles intact; Seal OK	845
1247	Redbud	07/14/11	D	1245		Baffles intact; Seal OK	615
1248	Redbud	07/13/11	D	1246		Baffles intact; Seal OK	1285
1249	Redbud	07/14/11	D	1251		Baffles intact; Seal OK	15
1250	Redbud	07/12/12	D	1252		Baffles intact; Clean cast & Lid	1085
1251	Redbud	07/14/11	D	1249		Baffles intact; Seal OK	620
1252	Redbud	07/12/12	D	1250		Baffles intact; Clean cast & Lid	650
1253	Redbud	07/13/11	S			Baffles intact; Seal OK	690
1254	Redbud	10/21/15	D	1256		Both baffles are intact. Casting ring was cleaned. Se	800
1255	Redbud	10/19/15	D>		W/ 1254 Dogwood	Both baffles are intact. Casting ring was cleaned. Se	190
1256	Redbud	10/21/15	D	1254		Both baffles are intact. Casting ring was cleaned. Se	85
1259	Redbud	07/14/11	S		New 3/94	Baffles intact; Seal OK	1505
1261	Redbud	07/15/11	S			Baffles intact; Seal OK	330
1263	Redbud	07/15/11	S			Baffles intact; Seal OK	265
1264	Redbud	08/26/15	D>		W/ 225 Dogwood	Both baffles are intact. Casting ring was cleaned. Se	155
1265	Redbud	07/15/11	S			Baffles intact; Seal OK	145
1266	Redbud	07/15/11	D	1269		Baffles intact; Seal OK	685
1269	Redbud	07/15/11	D	1266		Baffles intact; Seal OK	105
1805	Riverline	10/26/15	D	1825		Both baffles are intact. Casting ring was cleaned. Se	1425

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
1825	Riverline	10/26/15	D	1805		Both baffles are intact. Casting ring was cleaned. Se	1140
1830	Riverline	08/31/16	S			Baffles intact; Clean cast & Lid	1020
1835	Riverline	08/31/16	S			Baffles intact; Clean cast & Lid	440
2401	Riverview	08/05/16	S		On Graham	Baffles intact; Clean cast & Lid	1420
2402	Riverview	11/10/15	S		On Graham	Both baffles are intact. Casting and Seal are in good shape	600
2501	Riverview	08/23/16	S			Baffles intact; Clean cast & Lid	1445
2502	Riverview	08/23/16	D>		W/ 561 Brummitt Rd	Baffles intact; Clean cast & Lid	390
2601	Riverview	08/31/16	S			Baffles intact; Clean cast & Lid	790
501	Starwood	08/17/16	S		Shown as Dbl Tk on original	Baffles intact; Cast. & Seal Good shape	580
502	Starwood	08/08/16	S			Baffles intact; Clean cast & Lid	1255
520	Starwood	08/02/16	S			Baffles intact; Clean cast & Lid	570
521	Starwood	07/28/11	D>		W/ 1765 In Bdry Shown as Sgl Tk on Original	Baffles intact; Seal OK	235
1601	Starwood	10/27/15	S		On In Bdry	Baffles intact; Casting cleaned, Seal OK	470
1635	Starwood	08/02/16	D	1665	On Riverline	Baffles intact; Clean cast & Lid	895
1660	Starwood	08/31/16	D	1690		Baffles intact; Clean cast & Lid	525
1665	Starwood	08/02/16	D	1635		Baffles intact; Clean cast & Lid	1270
1690	Starwood	08/31/16	D	1660		Baffles intact; Clean cast & Lid	545
1695	Starwood	07/28/16	S			Baffles intact; Clean cast & Lid	1475
1730	Starwood	07/28/16	D	1760		Baffles intact; Clean cast & Lid	275
1735	Starwood	08/02/16	S			Baffles intact; Clean cast & Lid	1145
1760	Starwood	07/28/16	D	1730		Baffles intact; Clean cast & Lid	160
1765	Starwood	08/02/16	S			Baffles intact; Clean cast & Lid	1240
1795	Starwood	07/28/16	S			Baffles intact; Clean cast & Lid	370
1250	Trillium	10/22/15	S			Baffles intact; Casting cleaned, Seal OK	1345
1251	Trillium	10/22/15	S			Baffles intact; Casting cleaned, Seal OK	295
1252	Trillium	10/23/15	S			Baffles intact; Casting cleaned, Seal OK	475

LEGENDS

NO SCHEDULING REQUIRED UNTIL 2017

Other Up dates/corrections to information

Note: Properties with ***/*/12 Pump Dates** will be scheduled for **2017 Spring Clean Outs** for their 5 year cycle.

Date 2011 Spring Clean Out Schedule Completed 09/15/11 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2012 Clean Out Schedule Completed 08/15/12 By D&M

Date 2015 Fall Clean Out Schedule Completed 11/10/15 By D&M. Added Tank Cover Seal and Video Inspection column.

Date 2016 Fall Clean Out Schedule Completed 9/30/16 By D&M. Added Tank Cover Seal and Video Inspection column.

Lid Insp Tank Lids, seats wire brushed and o-rings inspected/replaced as req'd by D&M_Cmpl'd 3/8/12

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results	Address Account No.
1254	Trillium	10/21/15	S			Baffles intact; Casting cleaned, Seal OK	420
1251	Violet	08/23/16	S			Baffles intact; Clean cast & Lid	1300
1252	Violet	08/23/16	S			Baffles intact; Clean cast & Lid	530
332	Wake Robin	10/23/15	S			Baffles intact; Casting cleaned, Seal OK	1355
392	Wake Robin	08/20/15	D>		w/ 205 Dogwood	Baffles intact; Casting cleaned, Seal OK	870
1260	Wake Robin	10/23/15	D	1266		Baffles intact; Casting cleaned, Seal OK	1365
1261	Wake Robin	10/23/15	D	1265		Baffles intact; Casting cleaned, Seal OK	1110
1265	Wake Robin	10/23/15	D	1261	New 1/98	Baffles intact; Casting cleaned, Seal OK	1535
1266	Wake Robin	10/23/15	D	1260		Baffles intact; Casting cleaned, Seal OK	290
1270	Wake Robin	10/23/15	D>		W/ 1570 In Bdry	Baffles intact; Casting cleaned, Seal OK	1055
1271	Wake Robin	08/26/16	D>		W/ 1650 In Bdry	Baffles intact; Clean cast & Lid	700